

令和7年度 第2処理施設放流水検査結果

[illegible]

單位:mg/l

項 目	排水基準	4月		5月		6月		7月		8月		9月		10月		11月		12月		1月		2月		3月				
PH	5.8～8.6	7.9	8.0	8.0	8.0	8.1	8.0	8.2	8.0	8.2	8.2	7.5	7.9	7.9	8.2													
COD	－	16	12	12	11	13	11	11	10	12	11	11	13	13	9.6													
BOD	60 以下	4.6	2.2	1.5	1.4	1.7	1.5	1.6	1.4	2.0	1.2	15	21	1.2	0.8													
SS	60 以下	2.9	4.8	4.0	3.7	4.2	5.0	5.6	2.4	5.7	2.9	1.6	4.4	3.0	1.5													
大腸菌群数	800 CFU/ml 以下			<10						<10																		
n－ヘキサン	5 以下			<0.5						<0.5																		
全窒素	120 以下	8.7	2.4	1.0	8.1	1.5	1.6	4.3	1.3	13.0	5.5	27.0	19	17	18													
全燐	16 以下			0.19						0.47																		
カドミウム	0.03 以下	<0.001						<0.001																				
シアン	1 以下	<0.1						<0.1																				
鉛	0.1 以下	<0.005						<0.005																				
六価クロム	0.2 以下	<0.01						<0.01																				
ヒ素	0.1 以下	<0.005						<0.005																				
総水銀	0.005 以下	<0.005						<0.005																				
アルキル水銀	検出されないこと	不検出						不検出																				
PCB	0.003 以下	<0.0005						<0.0005																				
ジクロロメタン	0.2 以下	<0.002						<0.002																				
四塩化炭素	0.02 以下	<0.0002						<0.0002																				
1, 2－ジクロロエタン	0.04 以下	<0.0004						<0.0004																				
1, 1－ジクロロエチレン	1 以下	<0.02						<0.02																				
シス－1, 2ジクロロエチレン	0.4 以下	<0.04						<0.04																				
1, 1, 1－トリクロロエタン	3 以下	<0.3						<0.3																				
1, 1, 2－トリクロロエタン	0.06 以下	<0.006						<0.006																				
トリクロロエチレン	0.3 以下	<0.03						<0.03																				
テトラクロロエチレン	0.1 以下	<0.01						<0.01																				
1, 3－ジクロロプロペン	0.02 以下	<0.002						<0.002																				
チウラム	0.06 以下	<0.006						<0.006																				
シマジン	0.03 以下	<0.003						<0.003																				
チオベンカルブ	0.2 以下	<0.02						<0.02																				
ベンゼン	0.1 以下	<0.01						<0.01																				
セレン	0.1 以下	<0.01						<0.01																				
有機リン	1 以下	<0.1						<0.1																				
ふっ素	8 以下	<0.8						<0.8																				
ほう素	10 以下	<1						<1																				
1,4－ジオキサン	0.5 以下	<0.05						<0.05																				
フェノール	5 以下	<0.05						<0.05																				
銅	3 以下	<0.04						<0.04																				
垂 鉛	2 以下	<0.15						<0.15																				
溶解性鉄	10 以下	0.13						0.09																				
溶解性マンガン	10 以下	0.31						0.06																				
全クロム	2 以下	<0.05						<0.05																				
アンモニア性窒素	－	<0.4	<0.4	<0.4	<0.4	<0.4	<0.4	<0.4	<0.4	<0.4	<0.4	25	5.3	<0.4	<0.4													
硝酸性窒素	－	4.1	1.1	0.3	4.1	0.3	0.5	0.3	0.3	11	4.6	1.4	11	15	14													
亜硝酸性窒素	－			<0.4						0.4																		
ダイオキシン類	10pg-TEQ/L				0.000069																							

※例 <0.1 0.1未満を表す

[illegible]